



## Supplemental Plan Check Corrections Sheet for Security Requirements (2011 LABC)

Plan Check / PCIS application number: \_\_\_\_\_

Job Address \_\_\_\_\_

P.C. Engineer \_\_\_\_\_ (E-mail: [firstname.lastname@lacity.org](mailto:firstname.lastname@lacity.org)) Phone \_\_\_\_\_

For instruction and other information, read the master plan check list attached.

Obtain the following Information Bulletins, Affidavits or forms from our web site ([www.ladbs.org](http://www.ladbs.org))

- 
- 
- 1. All entry doors to dwelling units or guest rooms shall be arranged so that the occupant has a view of the area immediately outside the door without opening the door. Such view may be provided by a door viewer, through windows located in the vicinity of the door or through view ports in the door or adjoining wall. (6706)
- 2. Screens, barricades, or fences made of a material which would preclude human climbing shall be provided at every portion of every roof, balcony, or similar surface which is within 8 ft. of the utility pole or similar structures. (6707)
- 3. Wood flush-type doors shall be 1 3/8" thick minimum with solid core construction. 91.6709.1 - Door stops of in-swinging doors shall be of one-piece construction with the jamb or joined by rabbet to the jamb. (6709.4)
- 4. Every door in a security opening for an apartment house shall be provided with a light bulb (60 watt min.) At a maximum height of 8 feet on the exterior. (6708)
- 5. All pin-type door hinges accessible from outside shall have non-removable hinge pins. Hinges shall have min. 1/4" dia. steel jamb stud with 1/4" min. protection. The strike plate for latches and holding device for projecting dead bolts in wood construction shall be secured to the jamb and the wall framing with screws no less than 2-1/2" long. (91.6709.5, 6709.7)
- 6. Provide dead bolts with hardened inserts; deadlocking latch with key-operated locks on exterior. Doors must be operable from the inside without a key, special knowledge, or special effort (latch not required in B, F, and S occupancies). (6709.2)
- 7. Straight dead bolts shall have a min. throw of 1" and an embedment of not less than 5/8", and a hook-shaped or an expanding-lug deadbolt shall have a minimum throw of 3/4". (6709.2)
- 8. The use of a locking system which consists of a deadlocking latch operated by a doorknob and a deadbolt operated by a non-removable thumb turn which is independent of the deadlocking latch and which must be separately operated, shall not be considered as a system which requires special knowledge or effort when used in dwelling units. The door knob and the thumb turn which operates the deadbolt shall not be separated by more than 8 inches.
- 9. Wood panel type doors must have panels at least 9/16 in. thick with shaped portions not less than 1/4 in. thick and individual panels must be no more than 300 sq. in. in area. Mullions shall be considered a part of adjacent panels except mullions not over 18 inches long may have an overall width of not less than 2 inches. Stiles and rails shall be of solid lumber in thickness with overall dimensions of not less than 1 3/8 inches and 3 inches in width. (91.6709.1 item 2)
- 10. Sliding doors shall be provided with a device in the upper channel of the moving panel to prohibit raising and removing of the moving panel in the closed or partially open position. (6710)
- 11. Sliding glass doors shall be equipped with locking devices and shall be so constructed and installed that they remain intact and engaged when subjected to the tests specified in Sec. 6717.1
- 12. Metal or wooden overhead or sliding doors shall be secured with a cylinder lock, padlock with a min. 9/32" diameter hardened steel shackle and bolted, hardened steel hasps, metal slide board, bolt or equivalent device unless secured electrically operated. (6711)
- 13. Provide metal guides at top and bottom of metal accordion grate or grille-type doors and cylinder locks or padlocks. Cylinder guards shall be installed on all cylinder locks whenever the cylinder projects beyond the face of the door or is otherwise accessible to gripping tools. (6712)
- 14. In B, F, M, and S occupancies, panes of glazing with at least one dimension greater than 5 in. but less than 48 in, shall be constructed of tempered or approved burglary-resistant material or protected with metal bars or grilles (6714)
- 15. Glazed openings within 40" of the door lock when the door is in the closed position, shall be fully tempered glass or approved burglary

