



Supplemental Plan Check Corrections Sheet for Fire District 1 and Very High Fire Hazard Severity Zone (2011 LABC)

Plan Check / PCIS Application No.: _____

Job Address _____ Date: _____

P.C. Engineer: _____ Phone: _____

(E-mail: firstname.lastname@lacity.org)

For instruction and other information, read the master plan check list attached.

Obtain the following Information Bulletins, Affidavits or forms from our web site (www.ladbs.org)

Information Bulletin No. P/BC 2008-023



A. FIRE DISTRICT 1

1. Type (IV) (V) building is not permitted in Fire District No 1. (7204.1)
2. Type IIB construction shall have at least : (7204.2)
 - G 2 hour fire-resistive construction for exterior walls within 10 feet of and facing a property line.
 - G 1 hour fire-resistive construction for exterior walls within 30 feet of and facing a property line or as required by Table 601, whichever is higher.
3. Type II buildings shall have at least:
 - G Exterior Load bearing walls located within 30 feet of common property line or an assumed property line shall be of 2 hour fire-resistive. (7204.6)
 - G Exterior non-bearing walls located within 30 feet of a common property line or an assumed property line shall as required by Table 601, but not less than 1 hour. (7204.6)
 - G Exterior walls located more than 30 feet from common property line or an assumed property line shall comply with Table 601 requirements. (7204.6)
4. Provide 1-hour fire-resistance-rated construction in non-sprinklered building (7204.5), other than automobile parking structures and buildings surrounded on all sides by a permanently open space of 30 feet or more, for:
 - G Walls & supporting members
 - G Floors & supporting members
 - G Roof and supporting members
5. Openings shall be protected by a fire assembly having a 3/4 hour fire resistive rating when the exterior wall is within 10' of a fire separation distance. (7204.3)
6. Exterior plastic veneer is not permitted. (7204.11)
 - a. Architectural trims shall be of approved noncombustible materials or fire-treated wood. (7204.7)
 - b. Permanent canopies shall comply with Section (7204.8)
7. Every story or basement with a floor surface elevation more than 4 ft lower than the highest elevation of the floor landing or tread of any required exit from that story shall be sprinklered. (7203.5)
8. Loading platform shall be enclosed and shall be firestopped into areas not exceeding 2,500 square feet. (7203.6)
9. Loading platform over 48 inches above the ground shall be of noncombustible material. (7203.6)
10. Roofed platform shall be of noncombustible material. (7203.6)
11. Provide Class A or B roofing. (7204.4, 1505.1)

B. VERY HIGH FIRE HAZARD SEVERITY ZONE (VHFHSZ) (701A.3.2, 7201.2, 7207)

1. Based on City maps, this project is located within Very High Fire Hazard Severity Zone (VHFHSZ). It shall Comply with requirements of Materials, systems & construction methods of Chapter 7A and Chapter 72. Add the following material specifications and/or notes/details to plans:

