

City of Los Angeles Department of Building and Safety
Elevator and Pressure Vessel Division
5 Year Hydraulic Test for Group II Elevators Installed Prior to October 25th, 1998
With Group II, III and IV Valves

Location of Elevator _____
(Street Address) (Zip Code)

Elevator State Number _____ Outside Diameter of Ram _____

Elevator Rated Load as shown on the data plate _____
(Capacity in Pounds)

Elevator Rated Speed as shown on the data plate _____
(Speed in Feet per Minute)

Test Type	Group II	Results
Up Speed with Rated Load	3071(j)(1)(A)1	FPM
Down Speed with Rated Load	3071(j)(1)(A)2	FPM
Running Pressure with Rated Load (P.S.I.)	3071(j)(1)(A)	P.S.I.
Relief Valve Set Pressure MAXIMUM 125% FOR ALL VALVES	3071(j)(1)(B)	P.S.I.
For Valve Only, Check One Box Only Group II <input type="checkbox"/> Group III <input type="checkbox"/> Group IV <input type="checkbox"/>		
Relief Valve Sealed	3071(j)(1)(B)	YES <input type="checkbox"/> Circle One NO <input type="checkbox"/>
Centrifugal Pump maximum pressure (induction motor)	ASME 303	
Movement of Elevator in 15 minutes with Rated Load <small>*Movement greater than ¼ inch is unacceptable without proper justification. *Justifications for greater than ¼ inch movement are to be filled out below.</small>	3071(j)(1)(C)	Movement in Inches
Pressure Switch is in compliance, if provided	3071(j)(1)(D)	YES <input type="checkbox"/> NO <input type="checkbox"/> N/A <input type="checkbox"/> Circle One
Metal or Fiber Tag attached to the pumping unit (Include: state number, date of test, name of person or firm who conducted the test)	3071(j)(2)	YES <input type="checkbox"/> Circle One NO <input type="checkbox"/>

Test Performed By _____

Signature of Elevator Mechanic Printed Name, CCCM (State) License #, Los Angeles Journeyman License # & Expiration Dates

Elevator Company & CQCC License # & Expiration Date Date Test Was Completed

*** Justifications for movement of elevator with full load that is greater than ¼ inches in fifteen minutes.**
California Code of Regulations, Title 8, Group II States:
3071(j)(1)(C) When the car with rated load is stopped at some elevation in the hoistway for a period of 15 minutes, and with the power to disconnected, the elevator does not move (drift or creep). Any change in car position which cannot be accounted for by visible oil leakage or liquid temperature change indicates a problem and the need for further inspection, test, or repairs.

Comments _____

Return To: City of Los Angeles
Department of Building and Safety
Elevator and Pressure Vessel Division
221 N. Figueroa St. 8th Floor
Los Angeles, CA 90012 Phone #: (213) 202-9844 Fax #: (213) 202-9922

As a covered entity under Title II of the Americans with Disabilities Act, the City of Los Angeles does not discriminate on the basis of disability, and upon request, will provide reasonable accommodation to ensure equal access to its programs, services and activities.