

**City of Los Angeles Department of Building and Safety
Elevator and Pressure Vessel Division
Safety Test Requirements for Traction Elevators installed prior to October 25th, 1998**

Location of Elevator _____
(Street Address) (Zip Code)

Elevator State Number _____

12 Month Test (1 Year) **Check One Box Only** **60 Month Test (5 Year)**

12 Month Test (No Load)	CODE NUMBER	PASSED	FAILED	N/A
Safety Test for Type A, B or C Safeties (Hand trip at slowest speed)	1001.4a1			
Safety Test (Wood Guide Rails)	1001.4a2			
Safety Test (Type A Safety with wood rails and without Governor)	1001.4a3			
60 Month Test (Full Load) in addition to the above required tests				
Inspection of Type A (Operate by Hand)	1001.4b1			
Safety Test for Type A, B or C Safeties (Hand Trip at Rated Speed)	1001.4b2			
Type B Safety Stopping distance with rated load (Tested for Compliance to Code)	1001.4b3			
Type A Safety stops and hold (sufficient travel of safety rollers or dogs after safety)	1001.4b4			
Governor Overspeed Switch (Operation)	1001.4b5			
Governor Overspeed Switch (Tested for Compliance to Code)	1001.4b5			
Governor Tripping Speed (Tested for Compliance to Code)	1001.4b5			
Metal Tag attached to safety-releasing carrier or to the Governor & Buffer (Date, type of test, name of person or firm who conducted the test)	1001.4b5	Attachment Location (Circle one or both) Governor and/or Safety		
Car & Counterweight Oil Buffers (Oil Level Test)	1001.5 to 1000.3a			
Car & Counterweight Oil Buffers (Plunger Return Test)	1001.5 to 1000.3b			
Car & Counterweight Oil Buffers (Load and Speed Test)	1001.5 to 1000.3c			

Test Perform By _____

Signature of Elevator Mechanic

Printed Name, CCCM (State) License #, Los Angeles Journeyman License # & Expiration Dates

Elevator Company & CQCC License # & Expiration Date

Date Test Was Completed

Comments

Return To: City of Los Angeles
Department of Building and Safety
Elevator and Pressure Vessel Division
221 N. Figueroa St. 8th Floor
Los Angeles, CA 90012 Phone #: (213) 202-9844 Fax #: (213) 202-9922