



Central/String Inverter Systems for One and Two Family Dwellings

SCOPE: Use this plan ONLY for utility-interactive central/string inverter systems not exceeding a system ac inverter output rating of 10kW on the roof of a one- or two-family dwelling or accessory structure. The photovoltaic system must interconnect to the load side of a single-phase ac service panel of nominal 120/240Vac with a busbar rating of 225A or less. This plan is not intended for bipolar systems, hybrid systems, or systems that utilize storage batteries, charge controllers, trackers, more than two inverters, or more than one dc combiner (non-inverter-integrated) per inverter. Systems must be in compliance with current California Building Standards Codes and local amendments of the authority having jurisdiction (AHJ). Other Articles of the California Electrical Code (CEC) shall apply as specified in 690.3.

MANUFACTURER'S SPECIFICATION SHEETS MUST BE PROVIDED for proposed inverter, modules, combiner/junction boxes, and racking systems. Installation instructions for bonding and grounding equipment shall be provided, and local AHJs may require additional details. Listed and labeled equipment shall be installed and used in accordance with any instructions included in the listing or labeling (CEC 110.3). Equipment intended for use with PV system shall be identified and listed for the application (CEC 690.4(D)).

Job Address: _____ Permit #: _____

Contractor/ Engineer Name: _____ License # and Class: _____

Signature: _____ Date: _____ Phone Number: _____

Total # of Inverters installed: _____ (If more than one inverter, complete and attach the "Supplemental Calculation Sheets" on pages 7 and 8 and the "Load Center Calculations" on page 8 if a new load center is to be used)

Inverter 1 AC Output Power Rating: _____ Watts
 Inverter 2 AC Output Power Rating (if applicable): _____ Watts
 Combined Inverter Output Power Rating: _____ ≤ 10,000 Watts

Location Ambient Temperatures (Check box next to which lowest expected temperature is used):

1) <input type="checkbox"/> Lowest expected ambient temperature for the location (T _L) = <u>Between -1 to -5</u> °C <input type="checkbox"/> Lowest expected ambient temperature for the location (T _L) = <u>Between -6 to -10</u> °C Average ambient high temperature (T _H) = <u>47</u> °C Note: For a lower T _L or a higher T _H , use the Comprehensive Standard Plan
--

DC Information:

Module Manufacturer: _____		Model: _____
2) Module V _{oc} (from module nameplate): _____ Volts	3) Module I _{sc} (from module nameplate): _____ Amps	
4) Module dc output power under standard test conditions (STC) = _____ Watts (STC)		
5) <u>DC Module Layout</u>		
Identify each source circuit (string) for inverter 1 shown on the roof plan with a Tag (e.g. A,B,C,...)	Number of modules per source circuit for inverter 1	Identify, by tag, which source circuits on the roof are to be paralleled (if none, put N/A)
		Combiner 1:
		Combiner 2:
Total number of source circuits for inverter 1: _____		



Central/String Inverter Systems for One and Two Family Dwellings

6) **Are DC/DC Converters used?** Yes / No If "No," skip to STEP#7. If "Yes," enter info below.

DC/DC Converter Model #: _____	DC/DC Converter Max DC Input Voltage: _____ Volts
Max DC Output Current: _____ Amps	Max DC Output Voltage: _____ Volts
Max # of DC/DC Converters in an Input Circuit: _____	DC/DC Converter Max DC Input Power: _____ Watts

7) **Max. System DC Voltage** – Use **A1** or **A2** for systems without dc/dc converters, and **B1** or **B2** with dc/dc converters.

A1. Module V_{oc} (STEP #2) = _____ x # in series (STEP #5) _____ x 1.12 (If -1≤T_L≤-5°C, STEP#1) = _____ V

A2. Module V_{oc} (STEP #2) = _____ x # in series (STEP #5) _____ x 1.14 (If -6≤T_L≤-10°C, STEP#1) = _____ V

Table 1. Maximum Number of PV Modules in Series Based on Module Rated V _{oc} for 600Vdc Rated Equipment (CEC 690.7)													
Max. Rated Module V _{oc} (*1.12) (Volts)	29.76	31.51	33.48	35.71	38.27	41.21	44.64	48.70	53.57	59.52	66.96	76.53	89.29
Max. Rated Module V _{oc} (*1.14) (Volts)	29.24	30.96	32.89	35.09	37.59	40.49	43.86	47.85	52.63	58.48	65.79	75.19	87.72
Max # of Modules for 600Vdc	18	17	16	15	14	13	12	11	10	9	8	7	6

Use for dc/dc converters. The value calculated below must be less than dc/dc converter max dc input voltage (STEP #6).

B1. Module V_{oc} (STEP #2) _____ x # of modules per converter (STEP #6) _____ x 1.12 (If -1≤T_L≤-5°C, STEP#1) = _____ V

B2. Module V_{oc} (STEP #2) _____ x # of modules per converter (STEP #6) _____ x 1.14 (If -6≤T_L≤-10°C, STEP#1) = _____ V

Table 2. Largest Module V _{oc} for <u>Single-Module</u> DC/DC Converter Configurations (With 80V AFCI Cap) (CEC 690.7 and 690.11)																
Max. Rated Module V _{oc} (*1.12) (Volts)	30.4	33.0	35.7	38.4	41.1	43.8	46.4	49.1	51.8	54.5	57.1	59.8	62.5	65.2	67.9	70.5
Max. Rated Module V _{oc} (*1.14) (Volts)	29.8	32.5	35.1	37.7	40.4	43.0	45.6	48.2	50.9	53.5	56.1	58.8	61.4	64.0	66.7	69.3
DC/DC Converter Max DC Input (STEP #6) (Volts)	34	37	40	43	46	49	52	55	58	61	64	67	70	73	76	79

8) **Maximum System DC Voltage from DC/DC Converters to Inverter** – Only required if "Yes" in STEP#6

Maximum System DC Voltage = _____ Volts

9) **Maximum Source Circuit Current**

Is Module I_{sc} below 9.6 Amps (STEP#3)? Yes / No (if "No," use Comprehensive Standard Plan)

10) **Sizing Source Circuit Conductors**

Source Circuit Conductor Size = Min. #10 AWG copper conductor, 90°C wet (USE-2, PV Wire, XHHW-2, THWN-2, RHW-2)

For up to 8 conductors in roof-mounted conduit exposed to sunlight at least ½" from the roof covering (CEC 310)

Note: For over 8 conductors in the conduit or mounting height of lower than ½" from the roof, use Comprehensive Plan.

11) **Are PV source circuits combined prior to the inverter?** Yes / No

If **No**, use Single Line Diagram 1 with Single Line Diagram 3 and proceed to **STEP#13**.

If **Yes**, use Single Line Diagram 2 with Single Line Diagram 4 and proceed to **STEP#12**.

Is source circuit OCPD required? Yes / No

Source circuit OCPD size (if needed): 15 Amps

12) **Sizing PV Output Circuit Conductors** – If a Combiner box will NOT be used from [STEP #11],

Output Circuit Conductor Size = Min. #6 AWG copper conductor

13) **Inverter DC Disconnect**

Does the inverter have an integrated dc disconnect? Yes / No

If **yes**, proceed to STEP #14.

If **no**, the external dc disconnect to be installed is rated for _____ Amps (dc) and _____ Volts (dc)

14) **Inverter information**

Manufacturer: _____ Model: _____ Max. Continuous AC Output Current Rating: _____ Amps

Integrated DC Arc-Fault Circuit Protection? Yes / No (If "No" is selected, Comprehensive Standard Plan)

Grounded or Ungrounded System: GROUNDED UNGROUNDED



Central/String Inverter Systems for One and Two Family Dwellings

AC Information:

15) Sizing Inverter Output Circuit Conductors and OCPD

Inverter Output OCPD rating = _____ Amps (Table 2)

Inverter Output Circuit Conductor Size = _____ AWG (Table 2)

Table 3. Minimum Inverter Output OCPD and Circuit Conductor Size

Inverter Continuous Output Current Rating (Amps) (STEP#14)	12	16	20	24	28	32	36	40	48
Minimum OCPD Size (Amps)	15	20	25	30	35	40	45	50	60
Minimum Conductor Size (AWG, 75°C, Copper)	14	12	10	10	8	8	6	6	6

16) Point of Connection to Utility

Only load side connections are permitted with this plan. Otherwise, use Comprehensive Standard Plan.

Is the PV OCPD positioned at the opposite end from input feeder location or main OCPD location? Yes / No
If Yes, circle the **Max Combined PV System OCPD(s) at 120% value** as determined from **STEP 15 (or STEP S20)**, Busbar Rating, and Main OCPD as shown in Table 4.

If No, circle the **Max Combined PV System OCPD(s) at 100% value** as determined from **STEP 15 (or STEP S20)**, Busbar Rating, and Main OCPD as shown in Table 4.

Per 705.12(D)(2): [Inverter output OCPD size [STEP #15 or S20] + Main OCPD Size] ≤ [Bus size × (100% or 120%)]

Table 4. Maximum Combined Supply OCPDs Based on Busbar Rating (Amps) per CEC 705.12(D)(2)

Busbar Rating	100	125	125	200	200	200	225	225	225
Main OCPD	100	100	125	150	175	200	175	200	225
Max Combined PV System OCPD(s) at 120% of Busbar Rating	20	50	25	60*	60*	40	60*	60*	45
Max Combined PV System OCPD(s) at 100% of Busbar Rating	0	25	0	50	25	0	50	25	0

*This value has been lowered to 60A from the calculated value to reflect 10kW ac size maximum.

Reduction of the main breaker is not permitted with this plan. Otherwise, use Comprehensive Standard Plan.

17 & 18 & 19) Labels and Grounding and Bonding


This content is covered by the labels on Page 4 and the Single Line Diagram(s). For background information, refer to the Comprehensive Standard Plan.



Central/String Inverter Systems for One and Two Family Dwellings

Markings

CEC Articles 690 and 705 and CRC Section R331 require the following labels or markings be installed at these components of the photovoltaic system:



Informational note: ANSI Z535.4 provides guidelines for the design of safety signs and labels for application to products. A phenolic plaque with contrasting colors between the text and background would meet the intent of the code for permanency. No type size is specified, but 20 point (3/8") should be considered the minimum.

CEC 705.12 requires a permanent plaque or directory denoting all electric power sources on or in the premises.

SOLAR PV STANDARD PLAN - SIMPLIFIED

Central/String Inverter Systems for One and Two Family Dwellings




△ TAG	DESCRIPTION
1	SOLAR PV MODULE / STRING
2	DC/DC CONVERTERS INSTALLED? YES / NO (IF YES, STEPS 6 & 8 REQUIRED)
3	SOURCE CIRCUIT JUNCTION BOX INSTALLED?: YES / NO
4	SEPARATE DC DISCONNECT INSTALLED?: YES / NO
5	INTERNAL INVERTER DC DISCONNECT: YES / NO
6	CENTRAL INVERTER
7	LOAD CENTER INSTALLED?: YES / NO
8	PV PRODUCTION METER INSTALLED?: YES / NO
9	*SEPARATE AC DISCONNECT INSTALLED?: YES / NO
10	CONNECT TO INVERTER #2 (USE LINE DIAGRAM 2)

SINGLE-LINE DIAGRAM #1 – NO STRINGS COMBINED PRIOR TO INVERTER

CHECK A BOX FOR WHETHER SYSTEM IS GROUNDED OR UNGROUNDED: GROUNDED (INCLUDE GEC) UNGROUNDED

FOR UNGROUNDED SYSTEMS:
 - DC OCPD MUST DISCONNECT BOTH CONDUCTORS OF EACH SOURCE CIRCUIT
 - UNGROUNDED CONDUCTORS MUST BE IDENTIFIED PER 210.5(C). WHITE-FINISHED CONDUCTORS ARE NOT PERMITTED.

* Consult with your local AHJ and /or Utility



IF DC/DC CONVERTERS ARE USED, CHECK THE BOX BELOW THE CORRESPONDING CONFIGURATION

PARALLEL DC/DC CONVERTERS ON ONE SOURCE CIRCUIT (FIXED UNIT VOLTAGE DC/DC CONVERTERS)

DC/DC CONVERTERS ARE ALL RUN IN SERIES (FIXED SOURCE CIRCUIT VOLTAGE DC/DC CONVERTERS)

CONDUCTOR/CONDUIT SCHEDULE					
□ TAG	DESCRIPTION AND CONDUCTOR TYPE	CONDUCTOR SIZE	NUMBER OF CONDUCTORS	CONDUIT/CABLE TYPE	CONDUIT SIZE
A	USE-2 <input type="checkbox"/> OR PV-WIRE <input type="checkbox"/>				
	EGC/GEC:				
B					
	EGC/GEC:				
C					
	EGC/GEC:				
D					
	EGC/GEC:				

ENTER "N/A" WHERE SUITABLE FOR WHEN NOT USING CONDUIT OR CABLE AS PERMITTED BY CODE

SOLAR PV STANDARD PLAN - SIMPLIFIED

Central/String Inverter Systems for One and Two Family Dwellings




△ TAG	DESCRIPTION
1	SOLAR PV MODULE / STRING
2	DC/DC CONVERTERS INSTALLED? YES / NO (IF YES, STEPS 6 & 8 REQUIRED)
3	SOURCE CIRCUIT JUNCTION BOX INSTALLED?: YES / NO
4	COMBINER BOX (STEPS 11 & 12 REQUIRED)
5	SEPARATE DC DISCONNECT INSTALLED?: YES / NO
6	INTERNAL INVERTER DC DISCONNECT: YES / NO
7	CENTRAL INVERTER
8	LOAD CENTER INSTALLED?: YES / NO
9	PV PRODUCTION METER INSTALLED?: YES / NO
10	*SEPARATE AC DISCONNECT INSTALLED?: YES / NO
11	CONNECT TO INVERTER #2 (USE LINE DIAGRAM 4)

SINGLE-LINE DIAGRAM #2 – COMBINING STRINGS PRIOR TO INVERTER

CHECK A BOX FOR WHETHER SYSTEM IS GROUNDED OR UNGROUNDED: GROUNDED (INCLUDE GEC) UNGROUNDED

FOR UNGROUNDED SYSTEMS:
 - DC OCPD MUST DISCONNECT BOTH CONDUCTORS OF EACH SOURCE CIRCUIT
 - UNGROUNDED CONDUCTORS MUST BE IDENTIFIED PER 210.5(C). WHITE-FINISHED CONDUCTORS ARE NOT PERMITTED.


* Consult with your local AHJ and /or Utility



COMBINER CONDUCTOR/CONDUIT SCHEDULE					
□ TAG	DESCRIPTION AND CONDUCTOR TYPE	CONDUCTOR SIZE	NUMBER OF CONDUCTORS	CONDUIT/CABLE TYPE	CONDUIT SIZE
A1	USE-2 <input type="checkbox"/> OR PV-WIRE <input type="checkbox"/>				
	EGC/GEC:				
B1					
	EGC/GEC:				
C					
	EGC/GEC:				
D					
	EGC/GEC:				
E					
	EGC/GEC:				

NON-COMBINED STRINGS CONDUCTOR/CONDUIT SCHEDULE (IF APPLICABLE)					
□ TAG	DESCRIPTION AND CONDUCTOR TYPE	CONDUCTOR SIZE	NUMBER OF CONDUCTORS	CONDUIT/CABLE TYPE	CONDUIT SIZE
A2	USE-2 <input type="checkbox"/> OR PV-WIRE <input type="checkbox"/>				
	EGC/GEC:				
B2					
	EGC/GEC:				

ENTER "N/A" WHERE SUITABLE FOR WHEN NOT USING CONDUIT OR CABLE AS PERMITTED BY CODE



Plan Reviewer Initials: _____



Central/String Inverter Systems for One and Two Family Dwellings

Supplemental Calculation Sheets for Inverter #2

(Only include if no more than one additional inverter is used)

DC Information:

Module Manufacturer: _____		Model: _____														
S2) Module V_{oc} (from module nameplate): _____ Volts		S3) Module I_{sc} (from module nameplate): _____ Amps														
S4) Module dc output power under standard test conditions (STC) = _____ Watts (STC)																
S5) DC Module Layout																
Identify each source circuit (string) for inverter 1 shown on the roof plan with a Tag (e.g. A,B,C,...)	Number of modules per source circuit for inverter 1	Identify, by tag, which source circuits on the roof are to be paralleled (if none, put N/A)														
		Combiner 1:														
		Combiner 2:														
Total number of source circuits for inverter 1: _____																
S6) Are DC/DC Converters used? Yes / No If "No," skip to STEP#S7. If "Yes," enter info below.																
DC/DC Converter Model #: _____		DC/DC Converter Max DC Input Voltage: _____ Volts														
Max DC Output Current: _____ Amps		Max DC Output Voltage: _____ Volts														
Max # of DC/DC Converters in a source circuit: _____		DC/DC Converter Max DC Input Power: _____ Watts														
S7) Max. System DC Voltage – Use A1 or A2 for systems without dc/dc converters, and B1 or B2 with dc/dc converters.																
<input type="checkbox"/> A1. Module V_{oc} (STEP#S2) = _____ x # in series (STEP#S5) _____ x 1.12 (If $-1 \leq T_L \leq 5^\circ C$, STEP#S1) = _____ V <input type="checkbox"/> A2. Module V_{oc} (STEP#S2) = _____ x # in series (STEP#S5) _____ x 1.14 (If $-6 \leq T_L \leq -10^\circ C$, STEP#S1) = _____ V																
Table 1. Maximum Number of PV Modules in Series Based on Module Rated V_{oc} for 600Vdc Rated Equipment (CEC 690.7)																
Max. Rated Module V_{oc} (*1.12) (Volts)	29.76	31.51	33.48	35.71	38.27	41.21	44.64	48.70	53.57	59.52	66.96	76.53	89.29			
Max. Rated Module V_{oc} (*1.14) (Volts)	29.24	30.96	32.89	35.09	37.59	40.49	43.86	47.85	52.63	58.48	65.79	75.19	87.72			
Max # of Modules for 600Vdc	18	17	16	15	14	13	12	11	10	9	8	7	6			
Use for dc/dc converters. The value calculated below must be less than dc/dc converter max dc input voltage (STEP #S6).																
<input type="checkbox"/> B1. Module V_{oc} (STEP#S2) _____ x # of modules per converter (STEP#S6) _____ x 1.12 (If $-1 \leq T_L \leq 5^\circ C$, STEP#S1) = _____ V <input type="checkbox"/> B2. Module V_{oc} (STEP#S2) _____ x # of modules per converter (STEP#S6) _____ x 1.14 (If $-6 \leq T_L \leq -10^\circ C$, STEP#S1) = _____ V																
Table 2. Largest Module V_{oc} for Single-Module DC/DC Converter Configurations (With 80V AFCI Cap) (CEC 690.7 and 690.11)																
Max. Rated Module V_{oc} (*1.12) (Volts)	30.4	33.0	35.7	38.4	41.1	43.8	46.4	49.1	51.8	54.5	57.1	59.8	62.5	65.2	67.9	70.5
Max. Rated Module V_{oc} (*1.14) (Volts)	29.8	32.5	35.1	37.7	40.4	43.0	45.6	48.2	50.9	53.5	56.1	58.8	61.4	64.0	66.7	69.3
DC/DC Converter Max DC Input (STEP #6) (Volts)	34	37	40	43	46	49	52	55	58	61	64	67	70	73	76	79



Central/String Inverter Systems for One and Two Family Dwellings

S8) Maximum System DC Voltage from DC/DC Converters to Inverter – Only required if “Yes” in STEP#S6
 Maximum System DC Voltage = _____ Volts

S9) Maximum Source Circuit Current
 Is Module I_{sc} below 9.6 Amps (STEP#S3)? Yes / No (if “No,” use Comprehensive Standard Plan)

S10) Sizing Source Circuit Conductors:
Source Circuit Conductor Size = Min. #10 AWG copper conductor, 90°C wet (USE-2, PV Wire, XHHW-2, THWN-2, RHW-2)
 For up to 8 conductors in roof-mounted conduit exposed to sunlight at least ½” from the roof covering (CEC 310)
Note: For over 8 conductors in the conduit or mounting height of lower than ½” from the roof, use Comprehensive Plan.

S11) Are PV source circuits combined prior to the inverter? Yes / No
 If **No**, use Single Line Diagram 1 with Single Line Diagram 3 and proceed to **STEP#S13**.
 If **Yes**, use Single Line Diagram 2 with Single Line Diagram 4 and proceed to **STEP#S12**.
 Is source circuit OCPD required? Yes / No
 Source circuit OCPD size (if needed): 15 Amps

S12) Sizing PV Output Circuit Conductors – If a Combiner box will NOT be used from [STEP#S11],
 Output Circuit Conductor Size = Min. #6 AWG copper conductor

S13) Inverter DC Disconnect
 Does the inverter have an integrated dc disconnect? Yes / No
 If **yes**, proceed to STEP#S14.
 If **no**, the external dc disconnect to be installed is rated for _____ Amps (dc) and _____ Volts (dc)

S14) Inverter information:
 Manufacturer: _____ Model: _____ Max. Continuous AC Output Current Rating: _____ Amps
 Integrated DC Arc-Fault Circuit Protection? Yes / No (If “No” is selected, Comprehensive Standard Plan)
 Grounded or Ungrounded System: GROUNDED UNGROUNDED

AC Information:

S15) Sizing Inverter Output Circuit Conductors and OCPD:
 Inverter Output OCPD rating = _____ Amps (Table 3)
 Inverter Output Circuit Conductor Size = _____ AWG (Table 3)

Table 3. Minimum Inverter Output OCPD and Circuit Conductor Size									
Inverter Continuous Output Current Rating (Amps) (STEP#14)	12	16	20	24	28	32	36	40	48
Minimum OCPD Size (Amps)	15	20	25	30	35	40	45	50	60
Minimum Conductor Size (AWG, 75°C, Copper)	14	12	10	10	8	8	6	6	6

Load Center Calculations

(Omit if a load center will not be installed for PV OCPDs)

S20) Load Center Output:
 Calculate the sum of the maximum ac outputs from each inverter.
 Inverter #1 Max Continuous AC Output Current Rating[STEP#S14] _____ × 1.25 = _____ Amps
 Inverter #2 Max Continuous AC Output Current Rating[STEP#S14] _____ × 1.25 = _____ Amps
 Total inverter currents connected to load center (sum of above) = _____ Amps

Conductor Size: _____ AWG
 Overcurrent Protection Device: _____ Amps
 Load center busbar rating: _____ Amps

The sum of the ampere ratings of overcurrent devices in circuits supplying power to a busbar or conductor shall not exceed 120 percent of the rating of the busbar or conductor.

SOLAR PV STANDARD PLAN - SIMPLIFIED

Central/String Inverter Systems for One and Two Family Dwellings




△ TAG	DESCRIPTION
1	SOLAR PV MODULE / STRING
2	DC/DC CONVERTERS INSTALLED? YES / NO (IF YES, STEPS 6 & 8 REQUIRED)
3	SOURCE CIRCUIT JUNCTION BOX INSTALLED?: YES / NO
4	SEPARATE DC DISCONNECT INSTALLED?: YES / NO
5	INTERNAL INVERTER DC DISCONNECT: YES / NO
6	CENTRAL INVERTER
7	*SEPARATE AC DISCONNECT INSTALLED?: YES / NO
8	TO LOAD CENTER ON LINE DIAGRAM 1

SINGLE-LINE DIAGRAM #3 – ADDITIONAL INVERTER FOR DIAGRAM #1

INVERTER # 2

CHECK A BOX FOR WHETHER SYSTEM IS GROUNDED OR UNGROUNDED: GROUNDED (INCLUDE GEC) UNGROUNDED

FOR UNGROUNDED SYSTEMS:
 - DC OCPD MUST DISCONNECT BOTH CONDUCTORS OF EACH SOURCE CIRCUIT
 - UNGROUNDED CONDUCTORS MUST BE IDENTIFIED PER 210.5(C). WHITE-FINISHED CONDUCTORS ARE NOT PERMITTED.




* Consult with your local AHJ and /or Utility

CONDUCTOR/CONDUIT SCHEDULE					
□ TAG	DESCRIPTION AND CONDUCTOR TYPE	CONDUCTOR SIZE	NUMBER OF CONDUCTORS	CONDUIT/CABLE TYPE	CONDUIT SIZE
A	USE-2 <input type="checkbox"/> OR PV-WIRE <input type="checkbox"/>				
	EGC/EGC:				
B					
	EGC/EGC:				
C					
	EGC/EGC:				

ENTER "N/A" WHERE SUITABLE FOR WHEN NOT USING CONDUIT OR CABLE AS PERMITTED BY CODE

IF DC/DC CONVERTERS ARE USED, CHECK THE BOX BELOW THE CORRESPONDING CONFIGURATION



SOLAR PV STANDARD PLAN - SIMPLIFIED

Central/String Inverter Systems for One and Two Family Dwellings



△ TAG	DESCRIPTION
1	SOLAR PV MODULE / STRING
2	DC/DC CONVERTERS INSTALLED? YES / NO (IF YES, STEPS 6 & 8 REQUIRED)
3	SOURCE CIRCUIT JUNCTION BOX INSTALLED?: YES / NO
4	COMBINER BOX (STEPS 11 & 12 REQUIRED)
5	SEPARATE DC DISCONNECT?: YES / NO
6	INTERNAL INVERTER DC DISCONNECT: YES / NO
7	CENTRAL INVERTER
8	*SEPARATE AC DISCONNECT INSTALLED?: YES / NO
9	TO LOAD CENTER ON LINE DIAGRAM 3

SINGLE-LINE DIAGRAM #4 – ADDITIONAL INVERTER FOR DIAGRAM #2


INVERTER # 2

CHECK A BOX FOR WHETHER SYSTEM IS GROUNDED OR UNGROUNDED: GROUNDED (INCLUDE GEC) UNGROUNDED

FOR UNGROUNDED SYSTEMS:

- DC OCPD MUST DISCONNECT BOTH CONDUCTORS OF EACH SOURCE CIRCUIT
- UNGROUNDED CONDUCTORS MUST BE IDENTIFIED PER 210.5(C). WHITE-FINISHED CONDUCTORS ARE NOT PERMITTED.


* Consult with your local AHJ and /or Utility



COMBINER CONDUCTOR/CONDUIT SCHEDULE					
□ TAG	DESCRIPTION AND CONDUCTOR TYPE	CONDUCTOR SIZE	NUMBER OF CONDUCTORS	CONDUIT/CABLE TYPE	CONDUIT SIZE
A1	USE-2 <input type="checkbox"/> OR PV-WIRE <input type="checkbox"/>				
	EGC/GEC:				
B1					
	EGC/GEC:				
C					
	EGC/GEC:				
D					
	EGC/GEC:				

NON-COMBINED STRINGS CONDUCTOR/CONDUIT SCHEDULE (IF APPLICABLE)					
□ TAG	DESCRIPTION AND CONDUCTOR TYPE	CONDUCTOR SIZE	NUMBER OF CONDUCTORS	CONDUIT/CABLE TYPE	CONDUIT SIZE
A2	USE-2 <input type="checkbox"/> OR PV-WIRE <input type="checkbox"/>				
	EGC/GEC:				
B2					
	EGC/GEC:				

ENTER "N/A" WHERE SUITABLE FOR WHEN NOT USING CONDUIT OR CABLE AS PERMITTED BY CODE



Plan Reviewer Initials: _____