

# REQUEST FOR MODIFICATION OF BUILDING ORDINANCES

UNDER AUTHORITY OF L.A.M.C. SECTION 98.0403

<b>PERMIT APP. #:</b>		<b>DATE:</b>	
<b>JOB ADDRESS:</b>			
<b>Tract:</b>		<b>Block:</b>	
		<b>Lot:</b>	
<b>Owner:</b>		<b>Petitioner:</b>	
<b>Address:</b>		<b>Address:</b>	
City	State	Zip	Phone
<b>REQUEST</b> (SUBMIT PLANS OR ADDITIONAL SHEETS AS NECESSARY)		<b>CODE SECTIONS:</b> L.A.M.C 94.604.1	
Request to install and maintain plastic pipes for cold distilled or cold de-ionized water in a Type I building.			
<b>JUSTIFICATION</b> (SUBMIT PLANS OR ADDITIONAL SHEETS AS NECESSARY)			
Treated water is very aggressive and will corrode metal pipes.			
<b>Owner/Petitioner Name (Print)</b>		<b>(Signature)</b>	
		<b>Position</b>	
<b>FOR CITY DEPARTMENT'S USE ONLY BELOW THIS LINE</b>			
Concurrences required from the following Department(s)			
<input type="checkbox"/> Los Angeles Fire Department	Print Name _____	Sign _____	<div style="display: flex; justify-content: space-between;"> <div>Approved <input type="checkbox"/></div> <div>Denied <input type="checkbox"/></div> </div>
<input type="checkbox"/> Public Works Bureau of Engineering	Print Name _____	Sign _____	<div style="display: flex; justify-content: space-between;"> <div>Approved <input type="checkbox"/></div> <div>Denied <input type="checkbox"/></div> </div>
<input type="checkbox"/> Department of City Planning	Print Name _____	Sign _____	<div style="display: flex; justify-content: space-between;"> <div>Approved <input type="checkbox"/></div> <div>Denied <input type="checkbox"/></div> </div>
<input type="checkbox"/> Department of County Health	Print Name _____	Sign _____	<div style="display: flex; justify-content: space-between;"> <div>Approved <input type="checkbox"/></div> <div>Denied <input type="checkbox"/></div> </div>
<input type="checkbox"/> Other _____	Print Name _____	Sign _____	<div style="display: flex; justify-content: space-between;"> <div>Approved <input type="checkbox"/></div> <div>Denied <input type="checkbox"/></div> </div>
<b>DEPARTMENT ACTION</b>			
<input type="checkbox"/> GRANTED <input type="checkbox"/> DENIED		<i>Reviewed by: (Staff) (print)</i>	<i>Sign</i>
			<i>Date</i>
		<i>Action taken by: (Supervisor) (print)</i>	<i>Sign</i>
			<i>Date</i>
<b>NOTE: IN CASE OF DENIAL, SEE PAGE #2 OF THIS FORM FOR APPEAL PROCEDURES</b>			
<b>CONDITIONS OF APPROVAL (Continued on Page 2):</b>		<b>For Cashiers Use Only</b> <i>(PROCESS ONLY WHEN FEES ARE VERIFIED)</i>	
(See Attached Conditions of Approval on Page 3)			
<b>FEES</b>			
Appeal Processing Fee.. (No. of Items) =	X \$130 + \$39/addl	=	_____
Inspection Fee ..... (No of Insp.) =	X \$ 84.00	=	_____
Research Fee ... (Total Hours Worked) =	X \$104.00	=	_____
Subtotal .....		=	_____
Surcharge (One Stop).....	X 2%	=	_____
Surcharge (Systems Development).....	X 6%	=	_____
Total Fees .....		=	_____
Fees verified by:			
Print and Sign _____			

Permit App #:

Job Address:

## CONDITIONS OF APPROVAL (Continued from Page 1)

(See Attached Conditions of Approval on Page 3)

# CITY OF LOS ANGELES

## BOARD OF BUILDING AND SAFETY/DISABLED ACCESS

### COMMISSION APPEAL FORM

(Must be Attached to the Modification Request Form, Page 1)

**AFFIDAVIT – LADBS BOARD OF BUILDING AND SAFETY COMMISSIONERS – RESOLUTION NO. 832-93**

I, \_\_\_\_\_ do state and swear as follows:

(Print or Type Name of the Person Signing this Form)

1. The name and mailing address of the owner of the property (as defined in the resolution 832-93) at \_\_\_\_\_ as shown on the appeal application (LADBS Com 31) are correct, and
2. The owner of the property as shown on the appeal application will be made aware of the appeal and will receive a copy of the appeal.

I declare under PENALTY OF PERJURY that the foregoing is true and correct.

Owner's Name(s) \_\_\_\_\_  
(Please Type or Print) \_\_\_\_\_ (Please Type or Print)Owner's Signature(s) \_\_\_\_\_ (Two Officers' Signatures Required for Corporations)  
(Please Sign)Name of Corporation \_\_\_\_\_  
(Please Print Name of Corporation) \_\_\_\_\_ (Please Type or Print)

Dated this \_\_\_\_\_ day of \_\_\_\_\_ 20\_\_\_\_

**CALIFORNIA ALL-PURPOSE ACKNOWLEDGEMENT-----SIGNATURE(S) MUST BE NOTARIZED**State of **CALIFORNIA** County of \_\_\_\_\_ on \_\_\_\_\_before me, \_\_\_\_\_, personally appeared \_\_\_\_\_,  
Name, Title of Officer (e.g. Jane Doe, Notary Public) Name(s) of Signer(s)

who proved to me on the basis of satisfactory evidence to be the person(s) whose name(s) is/are subscribed to the within instrument and acknowledged to me that he/she/they executed the same in his/her/their authorized capacity(ies), and that by his/her/their signature(s) on the instrument in person(s), or the entity upon behalf of which the person(s) acted, executed the instrument. I **certify under PENALTY OF PERJURY under the laws of the State of California that the foregoing is true and correct.**

WITNESS my hand and official seal.

Signature

### APPEAL OF DEPARTMENT ACTION TO THE BOARD OF BUILDING AND SAFETY COMMISSIONERS/DISABLED ACCESS APPEALS COMMISSION

Applicant's Name \_\_\_\_\_

Applicant's Title \_\_\_\_\_

Signature \_\_\_\_\_

Date \_\_\_\_\_

**FEES**

Board Fee ..... (No. of Items)	X	\$130.00	=	_____
Inspection Fee ..... (No of Insp.) =	X	\$84.00	=	_____
Research Fee ... (Total Hours Worked) =	X	\$104.00	=	_____
Subtotal.....			=	_____
Surcharge .(One Stop).....	X	2%	=	_____
Surcharge .(Systems Development).....	X	6%	=	_____
Total Fees.....			=	_____

Fees verified by: \_\_\_\_\_

Print and Sign \_\_\_\_\_

**For Cashiers Use Only**

(PROCESS ONLY WHEN FEES ARE VERIFIED)

## SUPPLEMENTAL INFORMATION AND/OR SKETCH OF JOB CONDITION

### BASIS FOR APPROVAL-INFORMATION

For the Superintendent of Building or his designated agent to approve a request for modification or a request for alternate material or method of construction he must determine that special, individual reasons exist that make compliance with the strict letter of the ordinance impractical and that equivalency is provided for requests applicable to the State Housing Law. The resulting condition must be in conformance with the spirit and purpose of the ordinance involved. The applicant must provide sufficient information with this application to allow the above evaluation to be made.

### INFORMATION ON PROCEDURE FOR APPEAL FROM A DETERMINATION OR ACTION BY THE DEPARTMENT OF BUILDING AND SAFETY

Appeal from the determination or action of the Superintendent of Building or his designated agency may be made to the Board of Building and Safety Commissioners. To appeal, the appellant must give special individual reasons that make compliance with the strict letter of the ordinance impractical. Appeals pertaining to State Housing Law provisions require complete evidence to substantiate that the proposed design, material, or method of construction is at least equivalent to that prescribed by the Code. State such reasons or evidence on the front of this form or on a separate attachment.

DATE:

JOB ADDRESS:

CONDITIONS OF APPROVAL:

1. Plastic water piping may be installed within the building to distribute cold distilled or cold de-ionized water provided it is not installed in an attic, where exposed to temperatures over 120 degrees F, or in a building return air plenums, or penetrates supply air ducts.
2. Where piping penetrates fire resistive construction it shall either be insulated with material of equal or exceeding fire rating of the floor or wall being penetrated a minimum of two feet on each side of the penetration, or the penetration shall be caulked with an approved fire sealant of the appropriate fire rating.
3. All piping installed outside fire rated building enclosures, in concealed locations, shall be wrapped with an appropriate covering of approved, listed fire rated insulation material in accordance with the listing for the insulation material. The fire rating of the insulation material shall be one hour minimum except where it penetrates a fire-resistive enclosure (floor or wall) having a greater fire rating.
4. The insulation shall also be protected from damage or vandalism by installing sheet metal, plaster or similar non-combustible covering for minimum of two foot distance on each side of penetration.
5. It may be connected to industrial water protection and approved signs.
6. No potable water outlets shall be connected to a de-ionized water or distilled water system.
7. The piping shall be legibly labeled "For Laboratory Use Only," "De-ionized Water," "Distilled Water," "C.P. H<sub>2</sub>O," or similar designation.
8. Backflow protection is unnecessary unless required in the approval of the purifying device.