

Plan Check _____ Checked by: _____
 Permit Appl. # _____ An appointment is required for
 Job Address: _____ For appt. _____
 e-mail address: firstname.lastname@lacity.org

Your feedback is important, please visit our website to complete a Customer Survey at www.ladbs.org/LADBSWeb/customer-survey.jsf.

If you have any questions or need clarification on any plan check matters, please contact a plan check supervisor or call our Customer Hotline at (213) 482-0056.

NOTE: Information Bulletins (IB) may be obtained at www.lacity.org

APPLICATION

1. Provide fully dimensioned plot plan to scale, in ink, or copied to the application plot plan sheet provided. Show building lines, easements, lot size, zone boundaries, highway dedication lines, street center line, alley, parking spaces, fire walls, and location of all buildings. (Show type of construction, number of stories and use of all buildings.) Must agree with plot plan shown on plans. (106.3.2.1)
2. Project's valuation is \$ (_____). Additional plan check fee of _____ needs to be paid.
3. Complete the following application items: _____.
4. See the **Clearance Summary Worksheet** of the permit application for required clearances. Early attention to the clearances is suggested to avoid potential time delays.
5. **Prior to the issuance** of a building permit, the following is required from the agent of the owner:
 - a) An authorization letter from the owner to pull permit(s). Owner's signature must be verified by notarization or personal identification, **or**
 - b) The following is required from the contractor or his/her agent:
 - i). Certificate of Workers Compensation Insurance made out to the Contractors State License Board.
 - ii). Copy of City of LA business tax registration certificate or a newly paid receipt for one.
 - iii). Copy of contractors state license or pocket ID.
 - iv). Notarized letter of authorization for agents of contractor.
6. **Two sets of plans** and one set of calculations will be required when permit is issued. Plans shall be:
 - a) Quality blue or black line drawings with uniform and **light background** color.
 - b) Max. 36" x 48" size with minimum **1/8" lettering size**

- c) Sticky back details must produce prints without contrasting shades of background color.

PLAN DETAILS

1. All structural plan sheets and index sheet of calculations (showing number of pages) must be signed by the same civil/structural engineer licensed by the State of California. Plans and calculations for products designed by others must be reviewed and approved by the engineer of record for the project. (106.3.3)
2. Provide complete connection details of the exterior elements to the supporting structure showing compliance with ASCE 7-05, 13.5.3. Specify size, number, spacing, edge/end distances, and embedment of all fasteners.
3. Fasteners must have allowable load values specified by the building code or must be approved by a current Los Angeles City Research Report. (104.2.7)
4. Provide minimum vertical and horizontal reinforcement in precast concrete wall panels in accordance with ACI 318-08, Sec.16.4.2
5. Provide Veneer details. Show method of anchorage, size and spacing of anchors, and type of backing to comply with Section 1405 LABC.
6. Provide details of the approved fire stop material (system) used to seal voids created at the intersection of the curtain wall and the floor. Such material shall be securely installed and capable of preventing the passage of flame and hot gases. (713.3, 713.4)
7. Specify product name and current Los Angeles City Research Report number for the following products:
 - ~ Glass Fiber Reinforced Concrete (GFRC) Panels
 - ~ Steel Studs - except where stud sections are completely detailed on the plans and complete design calculations are provided for each section.
 - ~ Expansion Anchor
8. Specify product name and current Evaluation Report (ESR Report #) or Los Angeles City Research Report number for the following products:
 - ~ Caulking Sealant
 - ~ Exterior Finish and Insulation System
 - ~ Fire-Rated Expansion Joint
 - ~ Fire safing system for voids created between exterior curtain wall and floor intersection of rated floor/ceiling assembly.
9. Structural observation is required by IB P/BC 2008-24. Clearly indicate elements to be observed at each construction stage where observation is required. Provide required notes on plans (Sec.1710)

CALCULATIONS

1. The horizontal seismic design force (F_p) shall be determined in accordance with ASCE 7-05, 13.3.1

$$F_p = \frac{0.4a_p S_{DS} W_p}{\left(\frac{R_p}{I_p}\right)} \left(1 + 2 \frac{Z}{h}\right) \quad (13.3-1), \quad \leq F_p = 1.6 S_{DS} I_p W_p \quad (13.3-2)$$

$$F_p \text{ shall not be taken less than } 0.3 S_{DS} I W_p \quad (13.3-3)$$

2. Component amplification factor, a_p , for the fasteners of the connecting system of an exterior non-structural wall element shall be taken as 1.25 (ASCE 7-05, Table 13.5-1)
3. Component response modification factor, R_p , for the fasteners of the connecting system of an exterior non-structural wall element shall be taken as 1.0 (ASCE 7-05, Table 13.5-1).
4. Exterior nonstructural wall panels or elements that are attached to or enclose the structure shall be designed to accommodate the seismic relative displacements defined in section 13.3.2 and movements due to temperature changes. Such elements shall be supported by means of positive and direct structural supports or by mechanical connections and fasteners in accordance with the following requirements: (ASCE 7-05, Section 13.5.3)
 - ~ Connections and panel joints shall allow for the story drift caused by relative seismic displacements (D_p) determined in Section 13.3.2 or 0.5in, whichever is greatest.
 - ~ Connection to permit movement in the plane of the panel for story drift shall be sliding connections using slotted or oversize holes, connections that permit movement by bending of steel, or other connections that provide equivalent sliding or ductile capacity
 - ~ The connecting member itself shall have sufficient ductility and rotation capacity to preclude fracture of the concrete or brittle failures at or near welds.
 - ~ All fasteners in the connecting system such as bolts, inserts, welds, and dowels and the body of the connectors shall be designed for the force (F_p) determined by Section 13.3.1 with values of R_p and a_p taken from Table 13.5-1 applied at the center of mass of the panel.
 - ~ Where anchorage is achieved using flat straps embedded in concrete or masonry, such straps shall be attached to or hooked around reinforcing steel or otherwise terminated so as to effectively transfer forces to the reinforcing steel or to assure that pullout of anchorage is not the initial failure mechanism.

5. Out of plane bending or deformation of a component or system shall not exceed the deflection capability of component or system (ASCE7-05 13.5.5)
6. Nonstructural component anchorage shall be designed per ASCE7-05 13.4
7. Wind load design should comply with ASCE 7-05, Chapter 6
8. Glass in glazed curtain walls shall be designed and installed in accordance with Section 13.5.9 (ASCE 7-05, 13.5.4)
9. Glass in glazed curtain walls shall be firmly supported on all four sides, except as allowed by 2403.2. The load resistance of glass under uniform load with continuous lateral support on four sides shall be determined in accordance with ASTM E-1304.1 (2404.1)
10. Where one or more sides of any pane of glass are not firmly supported, or are subject to unusual load conditions, detailed construction documents, detailed shop drawings and analysis or test data assuring safe performance for the specific installation shall be prepared by the engineer of record for approval. (2403.2)
11. Height and fire-resistance requirements for curtain wall spandrels shall comply with 705.8.5 (714.5)
12. Glazing in the following areas must be impact hazard safety glass:
 - ~ Guards and railings regardless of area or height above a walking surface.
 - ~ Within 24-inches of the door's edge where the bottom of the exposed edge of the glazing is less than 60-inches above the walking surface.
 - ~ Glazing less than 60" above the walking surface and which is within 36" horizontally of a stair, landing, or ramp.
 - ~ Glazing less than 60" above the nose of a tread and within 60" horizontally of the bottom tread of a stairway. (2406.4)
13. Provide site plan showing property lines, adjacent streets and public ways, and all buildings within the same property to verify fire resistive requirements for the exterior curtain walls. (Table 602, 705)

NOTES ON PLANS

1. Precast Concrete Panel shall be manufactured under controlled plant conditions by licensed fabricator approved by the City of Los Angeles. (108.11, 1704.2.2)
2. Corrosion of aluminum caused by contact with dissimilar metals shall be prevented by proper design considerations and installation procedures in accordance with Specification for aluminum sheet metal work in building construction Section 3.2 ????
3. A mockup panel is highly recommended to be reviewed by the product manufacturer's representative prior to installation and inspection to insure code compliance and proper installation. Such material or systems shall be securely installed and capable of

