

INFORMATION BULLETIN / PUBLIC - BUILDING CODE


REFERENCE NO.: LABC Sec.11B-403,404,405, Effective: 01/01/2020

408,504,505,802

DOCUMENT NO.: P/BC 2020-085 Revised: 12/02/2019


Previously Issued As: P/BC 2017-085

ACCESSIBILITY DETAILS FOR RAMPS, STAIRS & ELEVATORS



RAMP WITH INTERMEDIATE SWITCH BACK PLATFORM

FIGURE 11B-405.7 RAMP LANDING




RAMP WITH TURNING PLATFORM

RAMP LANDING AND DOORWAY

THESE DIAGRAMS ILLUSTRATE THE SPECIFIC REQUIREMENTS OF THESE REGULATIONS AND ARE INTENDED ONLY AS AN AID FOR BUILDING DESIGN AND CONSTRUCTION.

RAMPS



SIDEWALK OBSTRUCTIONS

11B-505.10.1 TOP AND BOTTOM EXTENSION AT RAMPS. Ramp handrails shall extend horizontally above the landing for 12 inches beyond the top and bottom of ramp runs. Extensions shall return to a wall, guard, or landing surface, or shall be continuous to the handrail of an adjacent ramp run.




FIGURE *11B-*505.10.1
TOP AND BOTTOM HANDRAIL EXTENSION AT RAMPS






FIGURE 11B-405.9.2 CURB OR BARRIER EDGE PROTECTION



THESE DIAGRAMS ILLUSTRATE THE SPECIFIC REQUIREMENTS OF THESE REGULATIONS AND ARE INTENDED ONLY AS AN AID FOR BUILDING DESIGN AND CONSTRUCTION.

DOORWAYS AT RAMP LANDINGS




DOORWAYS AT TOP LANDING SPACE OF A RAMP

DOORWAYS AT BOTTOM LANDING SPACE OF A RAMP




STAIRWAYS



NOTE; INNER HANDRAIL AT LANDINGS OF STAIRS THAT DOUBLE BACK OR IMMEDIATELY TURN SHALL BE CONTINUOUS AND SHALL NOT EXTEND INTO LANDING OR ACCESSIBLE ROUTE OF TRAVEL


X = EXTENSION OF HANDRAIL SHALL BE EQUAL TO THE TREAD WIDTH PLUS 12 INCHES MINIMUM



11B-504 STAIRWAYS



STAIRS







FIGURE 11B-505.4 HANDRAIL HEIGHT

FIGURE 11B-505.5 HANDRAIL CLEARANCE

FIGURE 11B-505.6
HORIZONTAL PROJECTIONS
BELOW GRIPPING SURFACE

AT STAIRS



As a covered entity under Title II of the Americans with Disabilities Act, the City of Los Angeles does not discriminate on the basis of disability and, upon request, will provide reasonable accommodation to ensure equal access to its programs, services and activities.

AT STAIRS



ELEVATORS




TABLE 11B-407.4.1 ELEVATOR CAR DIMENSIONS


MINIMUM DIMENSIONS				
DOOR LOCATION	DOOR CLEAR WIDTH	INSIDE CAR, SIDE TO SIDE	INSIDE CAR, BACK WALL TO FRONT RETURN	INSIDE CAR, BACK WALL TO INSIDE FACE OF DOOR
Centered	42 inches	80 inches	51 inches	54 inches
Side (off-centered)	36 inches	68 inches	51 inches	54 inches
Any	36 inches	54 inches	80 inches	80 inches
Any	36 inches	60 inches	60 inches	60 inches


^{1.} A tolerance of minus 5/8 inch (15.9 mm) is permitted.

^{2.} Other car configurations that provide a turning space complying with Section 11B-304 with the door closed shall be permitted.



ELEVATORS








FIGURE 11B-408.4.1 LIMITED-USE/LIMITED-APPLICATION (LULA) ELEVATOR CAR DIMENSIONS

Door and signal timing. The minimum acceptable time from notification that a car is answering a call or notification of the car assigned at the means for the entry of destination information until the doors of that car start to close shall be calculated from the following equation:

T = D/(1.5 ft/s) or T = D/(455 mm/s) = 5 seconds minimum where T equals the total time in seconds and D equals the distance (in feet or millimeters) from the point in the lobby or corridor 60 inches (1524 mm) directly in front of the farthest call button controlling that car to the centerline of its hoistway door. (11B-407.3.4)

Exceptions:

- 1. For cars with in-car lanterns, T shall be permitted to begin when the signal is visible from the point 60 inches (1524 mm) directly in front of the farthest hall call button and the audible signal is sounded.
- 2. Destination-oriented elevators shall not be required to comply with *Section 11B-*407.3.4.

Door delay. Elevator doors shall remain fully open in response to a car call for 5 seconds minimum. (11B-407.3.5)




FIGURE 11B-407.2.3.2
CAR DESIGNATIONS ON JAMBS OF
DESTINATION-ORIENTED ELEVATOR HOISTWAY
ENTRANCES




FIGURE 11B-407.2.3.1
FLOOR DESIGNATIONS ON JAMBS OF ELEVATOR HOISTWAY ENTRANCE